

LAMPIRAN





PEMERINTAH KABUPATEN BULELENG
DINAS KESEHATAN



UPTD LABORATORIUM KESEHATAN MASYARAKAT

JL.SERMA KARMA NO. SINGARAJA (0362) 23339

No Agenda : 95/VII/KAB/2019
Perihal : pemeriksaan Kimia Air Bersih
Contoh Berasal : Danau Beratan Titik Barat
Pengambil Sampel : Riyadh
Diambil/Diterima tgl. : 20-11-2019/ 20-11-2019
Kode Sampel : KAB / AD / 12

kepada :
Yth. Bapak/Ibu
Riyadh
di -
Tempat

No	PARAMETER	SATUAN	KADAR MAKSIMAL	HASIL PEMERIKSAAN	KETR.
A.	FISIKA				
1.	Bau	-	-	Tidak Berbau	Normal
2.	TDS	Mg/L	1500	26	Normal
3.	Kekeruhan	Skala NTU	25	0.21	Normal
4.	Rasa	-	-	Tidak Berasa	Normal
5.	Suhu	⁰ C	Suhu udara $\pm 3^0$ C	25	Normal
6.	Warna	Skala NTU	50	Tidak Berwarna	Normal
B	KIMIA				
	Anorganik				
1.	Besi	Mg/L	1	0.01	Normal
2.	Florida	Mg/L	1.5	0.00	Normal
3.	Kesadahan	Mg/L	500	8.81	Normal
4.	Klorida	Mg/L	600	12	Normal
5.	Mangan	Mg/L	0.5	0.04	Normal
6.	Nitrat sbg. N	Mg/L	10	0.24	Normal
7.	Nitrit sbg. N	Mg/L	1	0.00	Normal
8.	pH	Mg/L	6.5- 9	5	Rendah
9.	Sulfat	Mg/L	400	2.21	Normal
	Organik				
10.	Zat Organik (KmnO ₄)	Mg/L	10	4.42	Normal

Ketr. : Mengacu Kepada PERMENKES NO. 416/ MENKES / PER / IX / 1990

Kepala UPTD Lab. Kes. Mas
Kab. Buleleng
Made Sugiasa, ST
NIP. 19671020 198703 1 002

Mengetahui
Kepala Dinas Kesehatan
Kabupaten Buleleng
dr. Ni Made Sukarni
NIP. 19601121198703 2 005

Singaraja, 21 november 2019

Made Dayana Yudi Wardana, ST
NIP. 19840926 201001 1 013